

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Advantage Flooring  
16 Gibbs Street  
Arundel QLD 4214

**Test Number :** 21-003709  
**Issue Date :** 15/09/2021  
**Print Date :** 16/09/2021

**Sample Description** Clients Ref : "Ultimate Planks"  
Flooring planks  
Colour : Timber effect  
End Use : Flooring  
Nominal Composition : PVC with PU coating

AS ISO 9239.1-2003

### Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 22-07-2021

Date Tested 13-09-2021

CHF Value	1	2	3	Mean
Length	10.0	-	-	- kW/m <sup>2</sup>
Width	10.0	10.0	10.0	10.0 kW/m <sup>2</sup>
Smoke Value	1	2	3	Mean
Length	27	-	-	- %min
Width	50	79	45	58 %min
Melting				Yes

249506

53075


Page 1 of 2

Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Chris Campbell

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc (Hons)  
MANAGING DIRECTOR