

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

TEST REPORT

Client : Beaulieu of Australia Limited
166 Pearson Road
Yatala QLD 4207

Test Number : 22-000274
Issue Date : 31/01/2022
Print Date : 31/01/2022

Sample Description Clients Ref : "Splash of Colour"
Loop pile carpet tile
Nominal Composition : 100% Solution Dyed Nylon
Nominal Mass per Unit Area/Density : 18oz/yd²

AS 4586-2013
Appendix A

Slip Resistance Classification of New Pedestrian Surface Materials Dry Pendulum Test Method

Date of Testing 24/07/2017
Test Temperature 22 °C
Sample Preparation Tested as received without underlay
Pile Direction Length
Fixed/Unfixed Unfixed
Slider No 96 Batch No 67

Length	1	2	3	4	5	SRV
British Pendulum Number	73	74	75	75	74	74
Classification (Surface tested dry)						P5

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 02/09/2015 Slider prepared using P400 and 3µ lapping film

260329

56438

Page 1 of 1

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Fiona McDonald
APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR

0204/11/06